

Net Metering

Company
Rate
Code

Availability:

Available to all qualifying Member generators with a design capacity not to exceed 25 kW. The interconnected facility must operate in parallel with existing distribution facilities and intended use is to offset Member's electric requirements. This schedule is offered in compliance with Wyo. Stat. Ann. 37-16-101 to 104.

Z

Rate:

Energy only (per kWh)
Line loss (per kWh)

Rate
\$0.03205
\$0.00095

Condition of Service:

All Member generators are responsible for the costs associated with the construction, modification and maintenance of their facilities that are interconnected. Net metering facilities shall meet all safety and performance standards as established by the National Electric Code, the Institute of Electrical and Electronics Engineers, and Underwriters Laboratories. The Member generator shall provide, at their own expense, equipment capable of locking and isolating the net metering facility from the Association's system. The Association shall not be liable for a net metering facility that may cause loss or injury, including, death, to any third party.

Payment:

If the electricity supplied by the Association exceeds the Member generator production, the Member will be billed monthly for their consumption. If the production for the Member generator is greater than consumption, at the beginning of each calendar year, any remaining unused kWh credits upon a Member account shall be sold to the Association at the avoided cost rate. Payment or bill credit will be based upon metered quantities registered.

Advice Letter No. _____

Steve Johnson

Issue Date July 12, 2018

Decision or Auth No. _____

General Manager
Title

Effective Date _____